Williams Mobile Home Park 2019 Annual Drinking Water Quality Report

Is my water safe?

MD0070238

Williams Mobile Home Park is pleased to provide this annual water quality report for calendar year 2018. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and are pleased to announce we met all state and federal drinking water requirements last calendar year.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from and what are the potential sources of contamination?

The sources of water supply wells in Cecil County are unconfined fractured rock and unconsolidated Coastal Plain aquifers. The Williams Mobile Home Park's water system, located in the Piedmont Region of northwest Cecil County, is currently using six production wells that draw water from the Volcanic Complex of Cecil County. The susceptibility analysis is based on a review of the existing water quality data for the water system, the presence of potential sources of contamination in the individual assessment areas, well integrity, and the inherent vulnerability of the aquifer. It was determined that the Williams Mobile Home Park's water supply is susceptible to contamination by volatile organic compounds. The system is not susceptible to nitrates, synthetic organic compounds, and other regulated inorganic compounds. The system may be susceptible to radiological compounds. Wells 1 through 4 are not susceptible to microbiological pathogens. The susceptibility to microbiological contaminants for Wells 5 and 6 could not be determined at the present time due to insufficient sampling data. For more information on the source of your water and the significant potential sources of contamination, contact the Maryland Source Water Assessment Program at the Maryland Department of the Environment at (410) 537-3714 or visit on the web at: www.mde.maryland.gov

Why may there be contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- 1. Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- 2. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- 3. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- 4. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- 5. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected in your water. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, may be up to five years old.

| Contaminant | Date Sampled | MCLG | Action Level (AL) | 90 th Percentile | # sites over AL | Units | Violation | Typical Source |
|-------------|-----------------|------|----------------------|--------------------------------|--------------------|-------|-----------|--|
| Copper | 09/07/2016 | 1.3 | 1.3 | 0.06 | 0 | ppm | No | Erosion of natural deposits; leaching from wood |
| | | | | | | | | preservatives; corrosion of household plumbing systems |

| | | | | Highest | Ra | nge | | |
|---|--------------------|--------------------------|--------|-------------------|------|------|-----------|--|
| Contaminant (units) | Collection Date | MCLG | MCL | Level Detected | Low | High | Violation | Typical Source |
| Disinfectants and Disinfection By-Products: | | | | | | | | |
| Total Trihalomethanes (ppb) | 08/01/2017 | No goal for the total | 80 | 6 | 6 | 6 | No | Byproduct of chlorination |
| Haloacetic Acids HAA5 (ppb) | 08/01/2017 | No goal for the total | 60 | 3.65 | 3.65 | 3.65 | No | Byproduct of chlorination |
| Chlorine (ppm) | 2018 | MRDLG=4 | MRDL=4 | 1.2 | 0.8 | 1.2 | No | Water additive used to control microbes |
| Inorganic Contami | inants: | | | | | | | |
| Cadmium (ppb) | 12/26/2017 | 5 | 5 | 1.9 | 1.9 | 1.9 | No | Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints |
| Nitrate as Nitrogen (ppm) | 2018 | 10 | 10 | 2 | 0 | 1.5 | No | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Radioactive Conta | minants: | | | | | | | |
| Gross alpha excluding radon & uranium (pCi/L) | 07/06/2017 | 0 | 15 | 3.7 | 0 | 3.7 | No | Erosion of natural deposits |
| Volatile Organic Contaminants: | | | | | | | | |
| Chlorobenzene (ppb) | 2018 | 100 | 100 | 0.56 | 0 | 0.56 | No | Discharge from chemical and agricultural factories |

Important Drinking Water Definitions:

- MCLG: Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risks for safety. MCGL allows for margin of safety.
- MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- AL: Action Level. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- ALG: Action Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
- MRDLG: Maximum Residual Disinfectant Level Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbe contaminants.
- MRDL: Maximum Residual Disinfectant Level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbe contaminants.

Units of Measurement & Conversions:

NA: Not applicable ppm: parts per million, or milligrams per liter (mg/L)

pCi/L: picocuries per liter (a measure of radioactivity) ppb: parts per billion, or micrograms per liter (µg/L)

Nitrate

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

Lead

If present, elevated levels of lead can cause serious health problems, especially in pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Williams Mobile Home Park is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at http://www.epa.gov/safewater/lead.

Copper

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Cadmium

| Some people who drink water containing | cadmium in excess of | the MCL over many year | rs could experience kidney |
|--|----------------------|------------------------|----------------------------|
| damage. | | | |

Williams Mobile Home Park

For additional information or questions contact:

Sam McMichael

(610) 932-4330

Prepared by: Water Testing Labs of Maryland, Inc.

For more information on contaminants in drinking water and its effects go to www.wtlmd.com